



CHANGE ORDER RECOMMENDATION LETTER

January 11, 2024

Mr. John Storms
Oklahoma City Airport Trust
7100 Terminal Drive, Unit 937
Oklahoma City, OK 73159

Re: OCAT WRWA 2413 - Hangars 2, 3, and Metrea Building Roof Replacement
Wiley Post Airport

Subject: Recommendation of Change Order No. 01

Mr. Storms,

Guernsey has reviewed the Change Order Request #01 submitted by Globe Construction Company for the above referenced project. Guernsey recommends acceptance of Change Order Number 1 for an additional \$27,067.03 to overlay existing skylights with sheet metal, replace existing deteriorated vents in Hangars 2 and 3, and install roof drain inserts on the Metrea Building. These changes will extend the duration of the Contract eleven (11) days. All items are for betterment to OCAT in terms of life/safety and reduction of future maintenance costs.

Should you have any additional questions about this recommendation, please feel free to contact me.

Sincerely,
C.H. Guernsey & Company

Steve Scovel, NCARB
Sr. Architect, PM
Ph. 405-416-8258
Email steve.scovel@guernsey.us

REALIZE THE DIFFERENCE

5555 North Grand Boulevard
Oklahoma City, OK 73112-5507
405.416.8100

guernsey.us