



ATLAS Paving Company

P.O. Box 75727 • Oklahoma City, OK 73147 • Phone: (405) 947-2381 • Fax: (405) 947-3670 • www.atlaspavingok.com

July 12, 2022

City of Oklahoma City
Public Works Department/Engineering Division
420 W Main, Suite 700
Oklahoma City, OK 73102

RE: OKC Project PC-0796 Summit Place – Street Resurfacing/Repair
Request for Additional Pay Items

Mr. Thapa,

After investigation in the field, it was discovered by both Nash Construction and our inspector, Mr. Mike Harcrow, that the concrete repair work on Summit Place requires additional excavation below the specified depth. The additional depth requires the use of aggregate material to bring the grade to within the repair depth.

As such, we are requesting adding the following pay item by way of Change Order:

225-00 AGGREGATE BASE (TYPE A) 500 CY \$100.00/CY

This quantity is double the required amount to account for future failures, and we have drawn the price from our most recently awarded Residential Unit Price Contract, PM-0298.

Please contact our offices to discuss this request further.

Sincerely,



Jeff Smith
Project Manager