

CONCURRED



MEMORANDUM

Council Agenda
Item No. X. M
5/20/2025

The City of OKLAHOMA CITY

TO: Mayor and City Council

FROM: Craig Freeman, City Manager

Concurrence with the Oklahoma City Water Utilities Trust in receiving Oklahoma Department of Environmental Quality Permit to Construct, Project WT-0253, High Service Pump Station Electrical Improvements, Draper Water Treatment Plant. Ward 4.

Location:

Draper Water Treatment Plant

Background:

Oklahoma statutes require water and wastewater construction projects be permitted by Oklahoma Department of Environmental Quality (ODEQ). ODEQ requests that governing bodies formally acknowledge receipt of ODEQ permits.

The following permit was recently received from ODEQ:

ODEQ Permit No. WT000055250186

This permit provides for the assessment of the existing switchgear, conduits, and wiring in the high service pump station (HSPS) and includes the removal, relocation, and/or replacement of electrical equipment. The variable frequency drives (VFD) will be relocated to the auxiliary HSPS VFD room, and a new cooling unit will be installed to provide redundancy and improve system resiliency.

Review:

Utilities

Recommendation: Concur with the Oklahoma City Water Utilities Trust in receiving the permit.