



January 12, 2024

Oklahoma City Airport Trust
Attn: Jeff Mulder, Director of Airports
7100 Terminal Dr. Unit 937
Oklahoma City, OK 73159-0937

Re: Terminal Bldg Electrical Rehabilitation and Backup Generator
Wiley Post Airport

Subject: Recommendation of Amendment No. 01

Mr. Mulder,

FSB has reviewed the revised quantities submitted by Libra Electric Company for the above referenced project. FSB recommends acceptance of the Amendment for a credit of \$5,230.00 for the following items:

1. Decrease the contract amount by \$1,980.00 because the electrical feeder between Panels EP2 and EP3 was not replaced under this Contract.
2. Decrease the contract amount by \$3,250.00 because the electrical feeder between Panels LS and B was not replaced under this Contract.

A separate price was provided at the time of bid for the replacement of several feeders because the condition and wire type of the feeder was not known. During construction, it was determined that the feeders listed above did not need to be replaced.

Sincerely,
FSB

A handwritten signature in black ink, appearing to read 'Casey West'.

Casey West
Project Manager