



January 2, 2024

Oklahoma City Airport Trust  
Attn: Jeff Mulder, Director of Airports  
7100 Terminal Drive Unit 937  
Oklahoma City, OK 73159-0937

Reference: **Rehabilitate Terminal Access Roadways – Phase 2  
OCAT WRWA 2305**

Subject: **Recommendation of Change Order No. 3**

Dear Mr. Mulder:

CGE has reviewed Change Order Request No. 3 submitted by CGC for the subject project. CGE recommends the acceptance of Change Order No. 3 for the following items for a total amount of \$58,787.20 and an increase of 5 calendar days to the contract.

1. The first subject item adds the construction of a blind junction box to eliminate a conflict between proposed storm sewer improvements with an existing gas line between Terminal Drive and Air Cargo.
2. The second subject item adds bollards to provide a traffic barrier between the hourly parking garage exit ramp and Terminal Drive.
3. The third subject item is to provide additional temporary traffic control for the remainder of the contract length.

Should you have any questions, please contact the undersigned at 405.463.3369.

Sincerely,

**COWAN GROUP ENGINEERING, LLC**

A handwritten signature in blue ink, appearing to read 'Sean Fairbairn'.

Sean Fairbairn, PE, CFM  
Associate | Team Lead

SKF/skf