



CHANGE ORDER RECOMMENDATION LETTER

March 5, 2024

Mr. John Storms
Oklahoma City Airport Trust
7100 Terminal Drive, Unit 937
Oklahoma City, OK 73159

Re: OCAT WRWA 2406 – 6921 S. Meridian Old ARFF Building Roof
Will Rogers World Airport

Subject: Recommendation of Change Order No. 3

Mr. Storms,

Guernsey has reviewed the Change Order Request #3 submitted by Globe Construction Company for the above referenced project. Guernsey recommends acceptance of Change Order Number 3 for an additional \$1,891.72 to 1) provide approximately 20 gas pipe blocks to support the gas piping above the roof and 2) provide a ballasted antenna supports to avoid guy wire penetrations in the roof.

The abandoned gas piping has been removed from the roof but the remaining gas piping has wooden blocks that are showing signs of deterioration. Replacing the wooden blocks with proper supports will increase the longevity of the roof and piping. The existing antenna had guy wires fastened directly to the roof deck which introduced areas for possible leakage. The ballasted roof supports will eliminate roof penetrations and reduce future leaks/maintenance.

Should you have any additional questions about this recommendation, please feel free to contact me.

Sincerely,
C.H. Guernsey & Company

A handwritten signature in blue ink, appearing to read 'St Scovel'.

Steve Scovel, NCARB
Sr. Architect, PM
Ph. 405-416-8258
Email steve.scovel@guernsey.us

REALIZE THE DIFFERENCE

5555 North Grand Boulevard
Oklahoma City, OK 73112-5507
405.416.8100

guernsey.us