


February 25, 2025

Mr. Chris Browning, General Manager
Oklahoma City Water Utilities Trust
420 W. Main, Ste 500
Oklahoma City, Oklahoma 73102



Re: Permit No. WT000055240708
WT-0224 Loan 12 – Phase 1A Draper WTP Clearwell Improvements
PWSID No. 1020902

Dear Mr. Browning:

Enclosed is Permit No. WT000055240708 for site preparation, demolition of the three (3) existing 5 million-gallon rectangular clearwells, demolition of the existing recovery pump station, removal of existing ancillary electrical items, installation of 302 linear feet of 84-inch steel pipe, and installation of 105 linear feet of 8-inch DR-100 pipe with all appurtenances to serve the Oklahoma City Water Utilities Trust, Cleveland County, Oklahoma.

The project authorized by this permit should be constructed in accordance with the plans approved by this Department on January 29, 2025. Any deviations from the approved plans and specifications affecting capacity, flow or operation of units must be approved, in writing, by the Department before changes are made.

Receipt of this permit should be noted in the minutes of the next regular meeting of the Oklahoma City Water Utility Trust, after which it should be made a matter of permanent record.

We are returning one (1) set of the approved plans to you, one set (1) to your engineer and retaining one (1) set for our files.

RECEIPT OF THIS PERMIT DOES NOT CONSTITUTE AN AUTHORIZATION TO AWARD A CONSTRUCTION CONTRACT UTILIZING FUNDING UNDER THE DRINKING WATER STATE REVOLVING FUND (DWSRF) PROGRAM. DO NOT AWARD A CONSTRUCTION CONTRACT UNTIL YOU ARE AUTHORIZED TO DO SO.

Respectfully,

Brent Polise

Brent Polise
DWSRF Section
Water Quality Division

BP/CT/md

Enclosure

c: Zachary McIntosh, Regional Manager, DEQ
OKLAHOMA CITY DEQ OFFICE
Tom Crowley, P.E., Carollo Engineers
Dan Ethington, P.E., Carollo Engineers

PERMIT No. WT000055240708

WATER TREATMENT

PWSID No. 1020902

PERMIT TO CONSTRUCT

Pursuant to O.S. 27A 2-6-304, the Oklahoma City Water Utilities Trust is hereby granted this Tier I Permit to demolish the three (3) existing 5 million-gallon rectangular clearwells, demolish the existing recovery pump station, remove existing ancillary electrical items, install 302 linear feet of 84-inch steel pipe, and install 105 linear feet of 8-inch DR-100 pipe with all appurtenances to serve the Oklahoma City Water Utilities Trust, located in Section 19, T-10-N, R-1-W; Section 20, T-10-N, R-1-W; and Section 24, T-10-N, R-2-W, Cleveland County, Oklahoma, in accordance with the plans approved on January 29, 2025.

Sludge will be disposed of in accordance with applicable rules and regulations regarding the disposal of waste sludges.

By acceptance of this permit, the permittee agrees to operate and maintain the facility in accordance with the Public Water Supply Operation rules (OAC 252:631), and to comply with the State Certification laws, Title 59, Section 1101-1116 O.S. and the rules and regulations adopted thereunder regarding the requirement for certified operators.

This permit is issued subject to the following provisions and conditions.

- 1) That the recipient of the permit is responsible that the project receive supervision and inspection by competent and qualified personnel.
- 2) That construction of all phases of the project will be started within one year of the date of approval or the phases not under construction will be resubmitted for approval as a new project.
- 3) That no significant information necessary for a proper evaluation of the project has been omitted or no invalid information has been presented in applying for the permit.
- 4) That the Oklahoma Department of Environmental Quality shall be kept informed on occurrences which may affect the eventual performance of the works or that will unduly delay the progress of the project.
- 5) That the issuing of this permit does not relieve the responsible parties from any damage which may accrue as the result of the location and operation of the plant in this area.
- 6) That before placing this facility into service, at least two samples of the water, taken on different days, shall be tested for bacteria to show that it is safe for drinking purposes.
- 7) That any deviations from approved plans or specifications affecting capacity, flow or operation of units must be approved by the Department before any such deviations are made in the construction of this project.

PERMIT No. WT000055240708

WATER TREATMENT

PWSID No. 1020902

PERMIT TO CONSTRUCT

- 8) That any notations or changes recorded on the official set of plans and specifications in the Oklahoma Department of Environmental Quality files shall be part of the plans as approved.
- 9) That the water leaving the plant will be non-corrosive as determined by a calcium carbonate saturation index (langelier index), and the water shall contain at least 1.0 mg/l free chlorine or 2.0 mg/l of combined chlorine.
- 10) The issuance of this permit does not relieve the responsible parties of any obligations or liabilities which the permittee may be under pursuant to prior enforcement action taken by the Department.
- 11) That the permittee is required to inform the developer/builder that a DEQ Storm Water Construction Permit is required for a construction site that will disturb one (1) acre or more in accordance with OPDES, 27A O.S. 2-6-201 et seq. For information or a copy of the GENERAL PERMIT (OKR10) FOR STORM WATER DISCHARGES FROM CONSTRUCTION ACTIVITIES, Notice of Intent (NOI) form, Notice of Termination (NOT) form, or guidance on preparation of a Pollution Prevention Plan, contact the Storm Water Unit of the Water Quality Division at P.O. Box 1677, Oklahoma City, OK 73101-1677 or by phone at (405) 702-8100.

Failure to appeal the conditions of this permit in writing within 30 days from the date of issue will constitute acceptance of the permit and all conditions or provisions.



Candy Thompson, P.E., Manager, DWSRF Section
Water Quality Division

Oklahoma Drinking Water State Revolving Fund

PROPOSED ELIGIBLE FUNDING ITEMS

Plans & Specs

Date: 2/6/2025

Name of Project: Phase 1A Draper WTP Clearwell Improvements

Project No.: P40-1020902-12

Loan No.: ORF-24-0001-DW

Minor variations within an item are to be expected and will not affect its eligibility. Any changes in the items, or substantial changes within an item, however, will be considered ineligible unless reconsideration is specifically required and approved by the Department of Environmental Quality and the Oklahoma Water Resources Board.

[illegible]