

Planning Commission Minutes
October 24, 2024

(The agenda was filed with the City Clerk of The City of Oklahoma City at 7:35 a.m. on October 21, 2024)

10. (SPUD-1676) Application by Oklahoma City Urban Renewal Authority to rezone 1612 NE 16th Street from R-1 Single-Family Residential and R-2 Medium-Low Density Residential Districts to SPUD-1676 Simplified Planned Unit Development District. Ward 7.

The applicant was present. There were no protestors present.

RECOMMENDED APPROVAL.

MOVED BY NOBLE, SECONDED BY MEEK

AYES: CLAIR, POWERS, MEEK, PRIVETT, NEWMAN, GOVIN, NOBLE,
LAFORGE

ABSENT: PENNINGTON



STAFF REPORT
The City of Oklahoma City
Planning Commission
October 24, 2024

Item No. IV. 10.

(SPUD-1676) Application by Oklahoma City Urban Renewal Authority to rezone 1612 NE 16th Street from R-1 Single-Family Residential and R-2 Medium-Low Density Residential Districts to SPUD-1676 Simplified Planned Unit Development District. Ward 7.

I. GENERAL INFORMATION

A. Contacts

1. Applicant Representative

Name Mark Zitzow
Company Johnson & Associates
Phone 405-235-8075
Email mzitzow@jaokc.com

B. Case History

This is a new application.

C. Reason for Request

The purpose of this application is to allow a mix of single-family and two-family residences.

D. Existing Conditions

1. Size of Site: 0.81 Acres

2. Zoning and Land Use

	Subject Site	North	East	South	West
Zoning	R-1/R-2	R-1	R-1	R-1	R-1
Land Use	Undeveloped	Residential	Residential	Residential	Residential

3. Comprehensive Plan Land Use Typology Area: Urban – Medium (UM)

UM applies to fully urbanized areas of the city, most of which were built prior to the 1960s. Developments are expected to be larger in scale and have greater intensity and mixture of uses than developments found in UL. Development within UM areas should support efficient transit usage and provide pedestrian and bicycle access to retail, services, parks, and other destinations. Priorities for the UM areas include “infill” developments on vacant lots, rehabilitation of underutilized property, and development that supports revitalization of distressed neighborhoods.

II. SUMMARY OF SPUD APPLICATION

1. This site will be developed in accordance with the regulation of the **R-2, “Medium Low Density Residential” District** (OKC Zoning Ordinance, 2020, as amended), except that the following restrictions will apply:

The following use(s) will be the only use(s) permitted on this site:

- Community Recreation: Property Owners Association (8250.3)
- Low Impact Institutional: Residential-Oriented (8200.5)
- Single-Family Residential (8200.14)
- Two-Family Residential (8200.16), units are not required to be attached

2. **Maximum Building Height:**

The maximum height of any building shall be 35 feet.

3. **Maximum Building Size:** N/A

4. **Maximum Number of Buildings:**

The maximum number of buildings shall be per the base zoning.

5. **Maximum Building Coverage:**

The maximum building coverage, per lot, shall be 75%.

6. **Minimum Lot Size:**

The minimum lot size within this SPUD shall be 2,000 square feet.

7. **Minimum Lot Width:**

The minimum lot width within this SPUD shall be 25 feet per dwelling unit.

8. **Building Setback Lines:**

Front Yard: 10 feet, garages shall be required an 18-foot setback from the back of the sidewalk.

Side Yard: 3 feet

Rear Yard: 10 feet

Corner Side Yard: 3 feet

Setbacks between internally divided parcels shall be zero (0) feet, except as required by building and fire codes.

9. Sight-proof Screening:

Sight-proof fencing shall not be required for this SPUD.

10. Landscaping:

The subject site shall meet all requirements of Oklahoma City's Landscaping Ordinance in place at the time of development.

11. Signs:

Signage shall not be permitted for this SPUD.

12. Vehicular Access:

Access may be taken from NE 16th Street, NE 16th Terrace, NE 15th Street, N Kelham Avenue and/or N Missouri Ave where applicable.

13. Sidewalks:

There are existing sidewalks along NE 16th Street, NE 16th Terrace, N Kelham Avenue and NE 15th Street. Should the existing sidewalks be damaged or removed during construction, the developer shall be required to repair/reinstall said sidewalk.

Any new sidewalks or repair/replacement of existing sidewalks shall be provided in accordance with the City of Oklahoma City Municipal Code and ADA requirements at the time of construction of this SPUD.

II. OTHER DEVELOPMENT REGULATIONS:

1. Architecture:

Exterior building wall finish on all main structures (excluding the accessory structures), exclusive of windows and doors, shall consist of a minimum 70% brick veneer, rock, concrete board, stucco or stone masonry. No more than 30% wood or architectural metal shall be permitted. Architectural regulations do not apply to accessory structures.

2. Open Space: N/A

3. Street Improvements: N/A

4. Site Lighting:

The site lighting in this PUD shall be in accordance with Chapter 59, Article XII, Section 59-12350 of the Oklahoma City Municipal Code, 2020, as amended.

5. Dumpsters: N/A

6. Parking:

One (1) parking space per unit shall be required within this SPUD. Garages shall not be required within this SPUD. However, any garage, carport or other parking facility that is constructed, with the exception of driveway paving, shall be located behind the front wall of any primary dwelling.

The design of all parking facilities in this SPUD shall be in accordance with Section 59, Article X of the Oklahoma City Municipal Code, 2020, as amended.

7. Maintenance: N/A

8. Drainage:

Development of this parcel will comply with Chapter 16 of the Oklahoma City Municipal Code, 2020, as amended.

9. Subdivision:

Subdivision shall conform to the Oklahoma City subdivision Regulations, as amended.

Lot lines may be adjusted to realign the location of homes prior to the platting stage.

10. Other:

10.1 Common Areas: Not Required

III. SUPPORTING DOCUMENTS

Exhibit A: Legal Description
Exhibit B: Boundary Exhibit

III. REVIEW COMMENTS

This application was submitted to the following agencies, departments, and/or divisions for review and comment. An asterisk * indicates that the agency, department, and/or division responded with no adverse comments.

A. Outside Agencies

- 1. Oklahoma City-County Health Department (OCCHD)**
- 2. Oklahoma City Urban Renewal Authority (OCURA)**
- 3. Oklahoma Gas and Electric (OGE)**
- 4. Oklahoma Natural Gas (ONG)**
- 5. Oklahoma Water Resources Board (OWRB)**
- 6. School District(s) Oklahoma City**
- 7. Oklahoma Department of Transportation (ODOT)**

B. City Departments

- 1. Airports**
- 2. Central Oklahoma Transportation and Parking Authority (COTPA)**
- 3. Fire ***
- 4. Information Technology/Geographic Support**
- 5. Parks and Recreation**
- 6. Police**
- 7. Public Works**

a. Engineering

Storm Sewer Availability

- 1) The Public Works Drainage Division staff has reviewed the subject application. All development, new construction, and/or substantial improvements planned within the proposed area shall be subject to chapter 16 of the Oklahoma City Municipal Code.
- 2) Storm sewers in accordance with the City's Drainage Ordinance will be required. Development abutting section line roads with drainage flows that exceed the capacity of OKC standard ditch detail (D-100) will necessitate the installation of enclosed storm sewer and/or concrete channel. These improvements shall be placed to provide a minimum of 35' clearance distance from the centerline of the section. Concrete channels must be entirely outside public right-of-way.
- 3) A flood and/or drainage study will be required to establish finished floor elevations, common lot areas or private drainage easements. A final plat should not be submitted until the study has been reviewed and approved by the Public Works Department.
- 4) Plans for drainage improvements within the private drainage reserves and/or common areas must be submitted for review, and payment of inspection fees shall

be made prior to construction. Building permits will not be issued until construction is complete. If a subdivision abuts a stream, the private drainage easements and/or common area along stream shall extend to flow line of stream at a minimum.

- 5) Place the following note on the plat and construction plans: Maintenance of the Common Areas and/or Private Drainage Easements shall be the responsibility of the property owner. No structures, storage of material, grading, fill or other obstructions, including fences, either temporary or permanent shall be placed within the common areas and/or drainage easements shown.
- 6) Drainage easements shall be clearly denoted as public or private in owner's dedication, on the plat, and/or in the plat notes.
- 7) Construction within the limits of this SPUD will require an erosion control plan in accordance with EPA Storm Water Discharge permitting: CFR Vol. 57, No. 175, September 9, 1992. A copy of the EPA Notice of Intent (NOI) will be required prior to the issuance of work orders or permits for construction activities disturbing an area of 1/2 acre or greater.
- 8) Sidewalk shall be installed for all new construction and/or at the time of a residential use to a more intense use on all lots having frontage on public streets classified as a major or minor arterial.
- 9) All private roads /streets will have private storm sewer systems.
- 10) Engineer/developers will be contacting PW for detention determination before they submit their final plat and plans.

b. Streets, Traffic and Drainage Maintenance

c. Stormwater Quality Management

d. Traffic Services *

8. Utilities

a. Engineering

b. Solid Waste Management

- 1) The City can provide service provided there is sufficient space for the truck to maneuver to service the addition.

c. Water/Wastewater Quality

Water Availability

- 1) Existing 8"/6" water main(s) is located adjacent to the subject site(s).

- 2) Minimum ten (10) feet horizontal separation required from wastewater mains and five (5) feet for other utilities. Minimum two (2) foot vertical separation required for all utility crossings. All water mains must have a minimum cover of five (5) feet along section line roads and four (4) feet elsewhere.
- 3) Proposed and/or existing water mains must be located centrally within a twenty (20) feet wide or larger utility easement or right-of-way. No trees, signs, dumpster, fence, and/or structures shall be permitted over any proposed or existing utility main. An approved revocable permit must be obtained to have any private improvement located within any utility easement and/or right-of-way.
- 4) Dead-end water mains must be avoided when possible. All existing unused water services must be capped and abandoned at the water main in accordance with the City Standard Specifications.
- 5) In accordance with ODEQ regulations, the City provides water at a minimum pressure of 25 psi. The developer is responsible for designing and construction of all fixtures to provide adequate domestic and fire protection under minimum pressure conditions. The developer will be responsible for any failure of domestic or fire protection systems which require water pressure in excess of 25 psi. The developer is responsible for installing pressure reducers if necessary for protection of developer's service lines, plumbing, and fixtures.
- 6) All existing and/or proposed water meters must be located in the right-of-way and/or utility easement within grassy areas outside of sidewalks, driveways, streets, and paving.
- 7) All domestic and fire suppression services must have a separate water service connection. Fire hydrant spacing shall not exceed 500 feet and must be located within ten (10) of a hard surface (i.e. sidewalk, street, paving).
- 8) Supply capacity for development is not guaranteed and will be reviewed at time of review of construction documents.
- 9) Plat may be revised after review and approval of utility plans.

Wastewater Availability

- 1) An existing 10"/8" wastewater main(s) is located adjacent to the subject site(s).
- 2) Line capacity is not guaranteed and must be checked by the Engineer of Record and reviewed by the City.
- 3) The developer will be required to extend the City wastewater collection system to and across each lot or site within the subdivision in accordance with the City Standard Specifications and Private Development Design Manual.
- 4) Minimum ten (10) feet horizontal separation is required from water mains and five (5) feet for other utilities. Minimum two (2) feet vertical separation required for all crossings. All wastewater mains must have a minimum cover of four (4) feet and

depth no greater than eighteen (18) feet. Developer is responsible for remediating any failure to maintain the minimum four (4) feet of cover.

- 5) Wastewater main(s) must be centrally located in a twenty (20) feet wide easement or larger if necessary. No trees, signs, dumpster, fence, and/or structures shall be permitted over any proposed or existing utility main. An approved revocable permit must be obtained to have any private improvement located within any utility easement and/or right-of-way.
- 6) All existing unused private wastewater service connections must be abandoned and capped at the main in accordance with City Standard Specifications and Private Development Design Manual.
- 7) Plat may be revised after review and approval of utility plans.

9. Planning

a. Comprehensive Plan Considerations

1) LUTA Development Policies:

Site Design:

- Maintain historical lot and block sizes where possible and appropriate.
- Utilize Best Management Practices (BMP) for stormwater.

Location:

- Mixture of density, lot size and building scale is appropriate as long as land use compatibility is achieved.

Density: The Urban Medium Intensity LUTA outlines a density range of 10 to 40 dwelling units per acre.

National, state, and local permitting require basic best management practices for stormwater management. The SPUD would allow density within this range on the multiple parcels. This site has frontage along the following streets: NE 15th Street, NE 16th Street, NE 16th Terrace, North Kelham Avenue and North Missouri Avenue. The SPUD regulations allow access from any of these streets.

Pedestrian Connectivity:

- Provide sidewalk connections to nearby uses.

Sidewalks are currently available along portions of the subject site areas, specifically NE 15th Street, NE 16th Street, NE 16th Terrace, and North Kelham Avenue. The SPUD regulations require retention and upkeep of existing sidewalks but do not require sidewalks along North Missouri Avenue.

- 2) **Compatibility:** The comprehensive plan includes a land use compatibility matrix used to identify potential conflicts between major land use categories. When locating the proposed uses adjacent to existing residential uses or zoning, "Building Scale and Site Design" is a potential compatibility issue identified by the comprehensive plan. Projects in higher intensity LUTAs (UM) may be more appropriate for significant transitions of density, scale and mass.

Building Scale and Site Design: The comprehensive plan calls for mitigation measures for new projects if the setbacks are significantly deeper or more shallow than the predominant character of adjacent development; the building's orientation to the street differs from the predominant character of adjacent development; building size or street frontage dramatically differs from that of adjacent uses, the lot coverage (including buildings and paved areas) dramatically exceeds that of adjacent uses, or if buildings within 40 ft. of a single-family residential structure exceed a 3:1 ratio in height. *The SPUD requests a reduced lot size of 2,000 square feet per dwelling compared to 3,000 square feet per dwelling for duplexes; lot widths of 25 feet per dwelling (50 feet per duplex), and lot coverage of 75% compared to 50% in the base R-2 District. Setbacks are proposed at 10 feet in front except that garages will be setback 18 feet from back of sidewalks, compared to 20-25 feet in the base R-1 District, and three feet on the side instead of 5 feet on the interior or 15 feet on corner side yards. The proposed front setbacks may differ from existing homes depending on which block new homes are located, and to which street they front.*

3) Service Efficiency:

- Water: *Served*
- Sewer: *Fully Served*
- Fire Service: *Urban Response*

4) Environmentally Sensitive Areas: The following apply to the proposed development site:

- Riparian Areas: N/A
- Upland Forests: N/A
- Vulnerable Aquifers: The aquifer in this area is considered highly vulnerable to depletion. The comprehensive plan recommends preserving natural open spaces and utilizing low impact development techniques whenever possible in new developments in order to maintain water quality and allow for the infiltration of stormwater onsite. Low impact development techniques include, but are not limited to, using pervious surface materials wherever possible for the construction of driveways, parking areas, sidewalks, patios, etc., to promote increased water percolation and infiltration.

5) Transportation System: This site has frontage along the following streets: NE 15th Street, NE 16th Street, NE 16th Terrace, North Kelham Avenue and North Missouri Avenue. NE 16th Street is a Minor Connector Street, and the others mentioned are Neighborhood Streets, all in the Urban Low LUTA. The nearest transit (bus) service is located within a quarter mile to the east, along North Martin Luther King Avenue.

6) Other Development Related Policies

- Support diversity and integration of housing unit types and sizes in all land use typology areas in order to meet the diverse needs of households of different sizes, generational needs, incomes, and preferences. (SU-4)
- Require sidewalks on both sides of all streets in urban LUTAs. (C-7)

- Improve the functionality and efficiency of the street network by:
 - Providing direct connections from residential developments to nearby places and to each other.
 - Providing street and sidewalk stubs to adjacent vacant land in anticipation of future development.
 - Connecting new development to existing street and sidewalk stubs, and to existing trail, open space, and bicycle networks.
 - Reducing block sizes and use of dead-end streets.
 - Maintaining the existing street grid to preserve connectivity and mobility options. (C-11)
- Support and incentivize the adaptive use of existing buildings, infill development, and brownfield development. (G-10)
- Preserve mature, healthy trees and incorporate them into the design of new development or redevelopment projects to the greatest extent possible. (G-26)
- Encourage unified planning for all adjoining land owned or controlled by a project's developer to ensure proper circulation and land use relationships (SU-47)

b. Plan Conformance Considerations

The SPUD is requested in order to construct new single-family and/or two-family attached or detached homes on vacant lots within the Culbertson East Highland neighborhood. The subject site is comprised of four noncontiguous parcels generally located between NE 15th and NE 16th Streets, and between North Jordan and North Missouri Avenues. The SPUD requests modified R-2 regulations of a reduced lot size to 2,000 square feet per dwelling, minimum lot widths of 25 feet per dwelling (50 feet per duplex), and lot coverage of 75%. Setbacks are proposed at 10 feet in front except that garages will be setback 18 feet from back of sidewalks, and three feet on the side including corner side yards. Some lots have frontage on two streets. While the design of the new homes was unknown at the time of review, the proposed development is subject to the Oklahoma City Urban Renewal Authority's design specifications. The proposal to increase density in the Urban Medium LUTA is in conformance with UM density ranges and comprehensive plan goals to provide a mixture of residential housing types and infill development on vacant lots.

IV. STAFF RECOMMENDATION

Staff recommendations are advisory only and do not constitute Planning Commission decisions. Staff recommendations are based on a technical evaluation of information submitted at the time of review. Determination of conformance with policies contained in the comprehensive plan is the purview of the Planning Commission. Planning Commission decisions require a vote of five members to approve or deny an item. The Planning Commission may consider in its decision-making process any additional relevant information presented at the public hearing by the public, applicant, and/or City departments.

Approval of the application.

All Engineering Division and Water/Wastewater Utilities Division requirements must be met. Additional changes to the SPUD may be required during either Divisions review of construction plans and prior to City Council approval.


taj

Case No: SPUD-1676

Applicant: Oklahoma City Urban Renewal Authority

Existing Zoning: R-1 / R-2

Location: 1612 NE 16th St.



Note: "Subject" is located approximately 852' West of N. Martin Luther King Ave.




The City of
OKLAHOMA CITY

Simplified Planned Unit Development



0 100 200
Feet



SPUD-1676
NE 16th Street

Exhibit 'B'
Boundary Exhibit

+/-0.81 acres

 Subject Property



Johnson & Associates
1 E. Sheridan Ave., Suite 200
Oklahoma City, OK 73104
405.275.8875 FAX 405.275.8175

DRAWN BY: TERRY DICKS PLANNED BY:

3/1/24


5832

Case No: SPUD-1676

Applicant: Oklahoma City Urban Renewal Authority

Existing Zoning: R-1 / R-2

Location: 1612 NE 16th St.



Aerial Photo from 2/2022

Note: "Subject" is located approximately 852' West of N. Martin Luther King Ave.



The City of
OKLAHOMA CITY

Simplified Planned Unit Development



0 100 200 Feet