

**OKLAHOMA CITY WATER UTILITIES TRUST**

**APPROVAL SHEET**

**Project No. SE-0043**  
**Emergency Sanitary Sewer Repairs**  
**SW 29<sup>th</sup> Street between S Meridian to S Utah Ave**

**ADDENDUM NO. 1**

Prepared by  
Utilities Engineering


  
\_\_\_\_\_  
Racheal Pierce, P.E., Project Engineer



Recommended for Approval

  
\_\_\_\_\_  
Crystal L. Kowalik, P.E., Engineering Manager

  
\_\_\_\_\_  
Chris Browning, General Manager

  
\_\_\_\_\_  
Eric J. Wenger, P.E., City Engineer

**APPROVED** by the Trustees and signed by the Chairman of the Oklahoma City Water Utilities Trust this \_\_\_\_ day of \_\_\_\_\_, 20\_\_.

**ATTEST:**

\_\_\_\_\_  
Secretary

\_\_\_\_\_  
Chairman

**CONCURRED** by the Council and signed by the Mayor of the City of Oklahoma City this \_\_\_\_ day of \_\_\_\_\_, 20\_\_.

**ATTEST:**

\_\_\_\_\_  
City Clerk

\_\_\_\_\_  
Mayor

## Emergency Sanitary Sewer Repair Project No. SE-0043

### Questions and Responses form BidSync

#### **Question 1 on Overall Bid**

The plans shows 1000 LF of pipe bursting but the quantities have 100 LF of 8" PVC and 900 LF of Bursting. Where is the 100 LF of open cut, its not shown on the plans? (Submitted: Mar 18, 2022 7:16:11 AM CDT)

**Response:** *Bidding shall be for 100 L.F. of open trench construction and 900 L.F. of pipe bursting construction.*

#### **Question 2 on Overall Bid**

The quantities have deflection test and sewer leakage test. Are these only for the 100 LF of 8" PVC by open cut? (Submitted: Mar 18, 2022 7:17:24 AM CDT)

**Response:** *Testing shall be done for the entire installation.*